

# Sondex - S35-IS

|                              |           |
|------------------------------|-----------|
| <b>STATUS</b>                | På lager  |
| <b>REF. NR.</b>              | HE142     |
| <b>PLATE/TUBE</b>            | Plate     |
| <b>MANUFACTURE</b>           | Sondex    |
| <b>TYPE</b>                  | S35-IS    |
| <b>SERIAL NO.</b>            | 8103      |
| <b>KAPACITET KCAL/TIME</b>   | 475100    |
| <b>YEAR</b>                  | 1992      |
| <b>SURFACE M2</b>            | 8,08      |
| <b>WORKING PRESS/TEMP</b>    | 6 / 110   |
| <b>PLATE DIM. (L*W*H) CM</b> | 127*60*20 |



**SONDEX**



|                           |                    |      |        |
|---------------------------|--------------------|------|--------|
| PLATE HEAT EXCHANGER TYPE | S 35-1S            | YEAR | 1992   |
| MANUFACTURING NO.         |                    |      | 8103   |
| NOMINAL CAPACITY          | kcal/h             |      | 475100 |
| TRANSMISSION AREA         | m <sup>2</sup>     |      | 8.05   |
| MAX. WORKING PRESSURE     | kp/cm <sup>2</sup> |      | 6      |
| TESTING PRESSURE          | kp/cm <sup>2</sup> |      | 8      |
| MAX. WORKING TEMP.        | °C                 |      | 110    |
| MIN. ASSEMBLING MEASURE   | mm                 |      | 95     |



**IMPORTANT**  
1) The plate heat exchanger must be assembled under the stated minimum assembling measure.  
Please contact Sonden distributor if the plate heat exchanger is leaking when tightened to the minimum measurement.  
2) The starting up must be done without pressure shocks and against closed valves.

NOT

SONDEX . DK - 6000 KOLDING . DENMARK