

STATUS

Available

REF. NUMBER

G2287

ENGINE

Volvo Penta D70 A *154*2948

GENERATOR

Stamford MC334A. 1500 Rpm

VOLT

220

KVA

60

HZ

50

REMARKS

Rockford PTO. PTA-21119





A.C. GENERATOR TO BS 5000

No F 5175

TYPE	MC354A	V.V.A.	60	RATING	1000
P.F.	0.8	R.P.M.	1500	Hz	50 PHASE 3
VOLTS	220	AMPS	168	AMB. ENT. TEMP.	45
ROTOR INSULATION	F	CHAR. Wdg VOLTS		CRACKING AMPS	
STATOR INSULATION	F	EXCITATION VOLTS	3	EXCITATION AMPS	0.6

WARNING REFER TO INSTRUCTION BOOK BEFORE FLASH OR MEGGER TESTING.

NEWAGE STAMFORD

NEWAGE ENGINEERS LTD. ELECTRICAL DIVISION
P.O. BOX 17, STAMFORD, LINCOLNSHIRE, ENGLAND.